MASONRY VENEER TIE DESIGN FOR LOW TO MID-RISE WOOD-FRAME BUILDINGS



16 - 5155 Spectrum Way Mississauga, ON L4W 5A1



Box 44023 RPO Garside, Edmonton, AB T5V 1N6 Canadian Conseil Wood canadien Council du bois

99 Bank St #400,

Ottawa, ON

K1P 6B9

l en

PREPARED BY:

Dr. Mark Hagel Dr. David Moses Robert Jonkman

Acknowledgments

The authors would like to thank Andrew Payne, Yang Du Mary Alexander, Nicholle Miller, and Conroy Murray, for their review and recommendations to the document.

Abstract

Masonry veneer is an excellent addition to any wood-frame building, especially in mid-rise wood-frame building, where current building codes require a non-combustible cladding, like masonry. When designing the ties for the masonry veneer with wood-frame backup walls, there are important considerations. Differential movement between the wood-frame and the masonry veneer and the difference in rigidity between the wood-frame backup wall and the masonry veneer are two very important factors to consider. Differential movement can affect the selection of a corrugated strip tie vs. a slotted tie. Difference in rigidity between the backup and veneer can affect the tie spacing and layout as increased loads are imposed on ties that are supported by less rigid back-up walls according to the CSA-S304-2014 and CSA-A370-2014. The following technical aid provides guidance on design of ties for low to mid-rise wood-frame buildings.

Table of Contents

Typical Masonry Tie layout for Brick Veneer	Pg. 1
Backup Wall Stiffness	Pg. 1
Masonry Tie Type Selection	Pg. 2
Masonry Tie Design	Pg. 3

Disclaimer

This publication is intended for use by professionals who are knowledgeable and experienced in masonry and wood design and construction and who are competent to evaluate the limitations of the information provided herein. The publishers and contributors to these publications disclaim any and all responsibility and liability for the application of the information contained herein, and any injury or damages suffered as a result of the use or inability to use this information.

Figure 1: Typical Tie Layout for SPF Wood Stud Wall with Studs at 406 (16") O.C.



Back-up Wall Stiffness

The backup wall is considered flexible if its stiffness is less than 2.5 the stiffness of the un-cracked veneer.

Veneer stiffness = Em·Iveneer

Backup wall stiffness = Estud * Ibackup

Example: 90 mm brick and 2x6 SPF wood stud backup wall with studs at 406mm o.c. (ignore exterior plywood sheathing) with tie spacing 406mm (16") horizontal o.c. by 610mm (24") vertical o.c.

Veneer: $E_{brick} = 850 \times 13 \text{MPa} = 11,050 \text{MPa}$

$$I_{veneer} = \frac{b \cdot h^3}{12} = \frac{(1000 mm/m) \cdot (90 mm)^3}{12} = 6.075 x 10^7 mm^4$$

 E_{brick} · $I_{veneer} = 6.713 \times 10^{11} \text{ N-mm}$

2x6 backup: $E_{stud} = 8,550 \text{ MPa}$

$$I_{backup} = \frac{b \cdot h^3}{12} \left(\frac{1000 mm/m}{406.4 mm} \right) = \frac{(38.1 mm) \cdot (139.7 mm)^3}{12} \left(\frac{1000 mm/m}{406.4 mm} \right) = 2.13 \ x \ 10^7 mm^4$$

 $E_{stud} \cdot I_{backup} = 1.821 \times 10^{11} N$ -mm

$$E_{stud}$$
 $I_{backup} / E_{brick} \cdot I_{veneer} = 1.821 \text{ x } 10^{11} / 6.713 \text{ x } 10^{11} = 0.27 < 2.5 \Rightarrow$ flexible backing

Masonry Tie Type Selection

With respect to the masonry veneer, if the veneer is clay brick, the brick swells and increases in dimension while the wood-frame shrinks and decreases in dimension. With concrete masonry veneer product (such as concrete brick, or split face architectural concrete block) the veneer shrinks but by a less pronounced amount than the woodframing. The use of an appropriate masonry veneer tie must then be determined when integrating masonry veneer and wood-framed buildings. Corrugated strip ties (Figure 2a) can be used, however, according to CSA-A370-2014 – Connectors for masonry Clause 10.5.1.2e), corrugated strip ties are limited to use on masonry veneer not higher than 11 m (36') above local grade. Although not standardized in CSA-A370-2014, corrugated strip ties should only be used if masonry veneer is supported on shelf angles at every floor where differential movement is isolated to one floor by the presence of the shelf angle at each floor. In this case, differential movement is expected to be approximately 6 mm $(\frac{1}{4})$ or less and can be managed by a strip tie. Adjustable tie systems accommodate differential movement much better than corrugated strip ties (Figure 2b) because they typically have a 30 mm (1.2") to 50 mm (2") long slot to accommodate differential movement. Adjustable ties are ideal when the designer wishes to support 6.1 (20') to 11 m (36') of masonry veneer on the foundation with a wood-frame building as the slot can accommodate the cumulative differential movement between the veneer and the wood frame. CSA-A370-2014 also provides additional information on masonry tie selection for adequate corrosion protection depending on the location of the building.





Figure 2a): Adjustable Masonry Tie b) Pre-Bent Corrugated Strip Tie

Masonry Tie Design

I) Tie Loads

Seismic Load: $q_f = V_p = 0.3F_aS_a(0.2)I_ES_pW_p = 1.18$ kPa

Wind Load: $p = I_w q C_e C_g C_p = 0.96 kPa \implies q_f = 1.5 \cdot 0.96 kPa \implies 1.44 kPa \implies$ Wind load governs

If the back wall stiffness is $> 2.5 \cdot (EI)_{veneer}$ then **non-flexible backing** => tributary area (TA) is:

i) TA = Area acting on the tie (typically 406mm x 610mm or 16"x24")

Else Flexible Backing

ii) TA = greater of $(TA_1 = 2 \cdot TA \text{ per tie}, TA_2 = 0.4 \cdot TA \text{ on a vertical line of ties})$

 $C_f / T_f = 2 \text{ x} (1.44 \text{ kN/m}^2) \cdot (0.406 \text{ m}) \cdot (0.610 \text{ m}) = 0.71 \text{ kN}$ OR

 $T_f/C_f = 0.4 \text{ x} (1.44 \text{ kN/m}^2) \cdot (0.406 \text{ m}) \cdot (3.048 \text{ m}) = 0.71 \text{ kN}$

II) Tie Resistance

a) For a Slotted Adjustable V-Tie

Figure 2a): Adjustable BLOK-LOK V-tie b) Adjustable FERO V-tie



```
According to CSA-A370-2014 Ties must have a minimum P_{ult} = 1.0 \text{ kN} \Rightarrow P_r = \phi P_{ult}.
```

Pult is typically the limit of the development length of the mortar (substrate) and the tie. The actual steel tie has significantly larger strength when calculated according to the CSA-S16-2009 as the minimum acceptable diameter for the wire is 3.65 mm \pm 0.15mm and there are 2 legs that engage the mortar (Figure 2a and Figure 2b).

i.) Tie Withdrawal / Push Resistance Through Mortar

From CSA S370-2014 Clause 9.4.2.1.2 - $\phi = 0.90$ $T_r = \phi \cdot P_{ult} = 0.90 \cdot 1.00 \text{ kN} = 0.90 \text{ kN} / \text{per fastener} > 0.71$ OK $C_r = \phi \cdot P_{ult} = 0.90 \cdot 1.00 \text{ kN} = 0.90 \text{ kN}$ per fastener > 0.71 OK

ii.) Tension / Compression Resistance of the Steel Tie According to CSA-S16-2009

 $T_r = C_r = \phi \cdot F_y \cdot A_g \times 10^{-3}$

Where: $\phi = 0.90$ $F_y = 345 \text{MPa}$ $A_g = 22 \text{ mm x } 0.80 \text{ mm} = 17.6 \text{ mm}^2$

 $T_r = C_r = 0.90 \cdot 345 \text{ MPa} \cdot 17.6 \text{ mm}^2 = 5.46 \text{ kN} > 0.71 \text{ kN}$

b) For a Corrugated Strip Tie

According to CSA-A370-2014 Ties must have a minimum $P_{ult} = 1.0 \text{ kN} \Rightarrow P_r = \phi P_{ult}$.

 $P_{\rm ult}$ is typically the limit of the development length of the mortar (substrate) and the tie. The actual steel tie has significantly larger strength when calculated according to the CSA-S16-2009 as the minimum acceptable dimensions for a strip tie is 22 mm wide by 0.80 mm thick.

i.) Tie Withdrawal / Push Resistance Through Mortar

From CSA S370-2014 Clause 9.4.2.1.2 - $\phi = 0.90$	
$T_r = \phi \cdot P_{ult} = 0.90 \cdot 1.00 \text{ kN} = 0.90 \text{ kN}$ / per fastener > 0.71	ОК
$C_r = \phi \cdot P_{ult} = 0.90 \cdot 1.00 \text{ kN} = 0.90 \text{ kN}$ per fastener > 0.71	OK

ii.) Tension / Compression Resistance of Tie

 $P_{rw} = (\phi y_w) \cdot L_{pt} \cdot K_{SF} \cdot K_T \cdot K_D \cdot n_F \times 10^{-3}$ $\phi y_w = 28 \text{ N/mm} \text{ (From Table 7.4 of 2015 Wood Design Manual)}$ $L_{pt} = \frac{2}{3} \cdot 44.5 \text{ mm} = 29.7 \text{ mm} (\frac{2}{3} \text{ recommended in CSA-O86-2014})$ $K_{SF} = 1.0$ $K_T = 1.0$ $K_D = 1.15$ $n_F = 1 \text{ wood screw}$

 $P_{rw} = 28 N / mm \cdot 29.7 mm \cdot 1.0 \cdot 1.0 \cdot 1.15 x 10^{-3} = 0.96 kN > (T_f)_{fastener} = 0.71 kN$ OK

III) Tie Connection Design

(Tf / Cf) fastener = **0.71 kN**

Assumptions:

- SPF wood stud
- 19 gauge (0.91 mm) light gauge steel plate
- 1 No. 10 wood screw 1-3/4" (44.5 mm) in length, per tie

Fastener Withdrawal:

 $\mathbf{P}_{\mathrm{rw}} = (\phi y_w) \cdot L_{pt} \cdot K_{SF} \cdot K_T \cdot K_D \cdot n_F x \ 10^{-3}$

 $\phi y_w = 28$ N/mm (From Table 7.4 of 2015 Wood Design Manual) $L_{pt} = \frac{2}{3} \cdot 44.5 \text{ mm} = 29.7 \text{ mm} (2/3 \text{ recommended in CSA-O86-2014})$ $K_{SF} = 1.0$ $K_T = 1.0$ $K_D = 1.15$ $n_F = 1 \text{ wood screw}$

 $P_{rw} = 28 N / mm \cdot 29.7 mm \cdot 1.0 \cdot 1.0 \cdot 1.15 x 10^{-3} = 0.96 kN > (T_f)_{fastener} = 0.71 kN$ OK

Fastener Pull Through:

 $P_{pt} = 1,460$ N (From Table 7.5 of 2015 Wood Design Manual with 0.91mm plate)

$$P_{pt} = 1,460 \text{ N} \times 10^{-3} = 1.46 \text{ kN} > (C_f / T_f)_{\text{fastener}} = 0.71 \text{ kN}$$
 OK

5